



## **Pool Pre-Opening Checklist**

The following items must be in compliance before your pool can be opened to the public:

- ☐ Qualified Pool Operator (certificate of completion **MUST** be available onsite)
- ☐ Pool is in good repair before cleaning and filling (i.e. no cracks, smooth surface)
- ☐ Fence is in good repair and no more than 4" between slats
- ☐ Gates are self-closing and self-latching
- ☐ Regulation signs posted (i.e. "No Lifeguard on Duty", "No Diving", Bather Load)
- ☐ Standard telephone line or callbox at poolside is operational and has the capability of dialing "911"
- ☐ Address of the pool must be posted next to the standard telephone line or callbox
- ☐ Emergency lifesaving equipment is provided, accessible, and in good repair (shepherd's crook, ring buoy with rope, lifeline with floats)
- ☐ Standard first aid kit mounted in pool enclosure
- ☐ Water quality test kit (DPD kit) on premises
- ☐ Water pH is between 7.2 and 7.8
- ☐ Chlorine levels are accurate; 1.0-4.0 ppm for pools and 2.0-5.0 ppm for spas
- ☐ Bromine levels are accurate; 2.0-8.0 ppm for pools and 4-10 ppm for spas
- ☐ Chemical inline feeder is operational
- ☐ Flow meter is installed and operational
- ☐ Equipment rooms must be properly ventilated
- ☐ Pool water temperature is 70F° or above
- ☐ Spa/hot tub water temperature cannot exceed 104F°
- ☐ Steps, ladders and handrails are in good repair and structurally safe
- ☐ Depth markers are on deck and side walls of pool
- ☐ Depth markers for a spa are 3" in height and located on the exterior of the spa
- ☐ Operating records are current and legible

\*Please note this checklist is intended to highlight items which need to be completed for a pool pre-opening inspection. All items in compliance on the list do not guarantee a passing pre-opening inspection. Facility must be in compliance with the *Kansas City, MO Health Department's Public Health Rules & Regulations for the Operations & Maintenance of Swimming Pools & Bathing Facilities* to obtain a passing pre-opening inspection from the Kansas City, Missouri Health Department.



**KCMO HEALTH DEPARTMENT  
ENVIRONMENTAL PUBLIC HEALTH PROGRAM**  
2400 TROOST AVE, SUITE 3200  
KANSAS CITY, MO 64108  
Phone: (816) 513-6315 Fax: (816) 513-6290



**Public Health**

**Contacts by Name and District**

<b>Monica Dickes 513-9308</b>	<b>Andrea Beachem 513-9306</b>	<b>Lisa Fiorino 513-9313</b>	<b>Leah Ritter 513-9321</b>
64153	64154 64152 64151	64164 64155 64118	64156 64157 64158 64119

<b>Alex Kuestersteffen 513-6377</b>	<b>Kristi Eftink 513-6164</b>	<b>Belal Elyousef 513-6325</b>	<b>Aaron Niefert 513-6197</b>
64116 64105 64101 64102	64120 64161 64117 64123	64124 64106	64128 64127 64126 64129 64125

<b>Jennifer Sanchez 513-6196</b>	<b>Manmeet Hundal 513-6201</b>	<b>Jamie Shank 513-6206</b>	<b>Andrea Flowers 513-6205</b>
64108	64111	64110 64112	64132 64130 64109

<b>Brooke Hollingsworth 513-6178</b>	<b>Philip Ford 513-6180</b>	<b>Jenny Zweifel 513-6175</b>	<b>Christy Mann 513-6182</b>
64133 64136 64139 64138	64113 64137 64131	64114	64134 64146 64147 64145 64149